

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1140441

Product: Industrial switchgear

Type: RH 4

Rating: Ue=400/230 V, 50-60 Hz, Ie=10-6300 A, Icc = 9,5-176 kA, IP 40/20

Ordering firm: Global Business s.r.o.
Kostelec u Holešova 264, 768 43 Kostelec u Holešova, Czech Republic

Manufacturer: Global Business s.r.o.
Kostelec u Holešova 264, 768 43 Kostelec u Holešova, Czech Republic

Factories: Global Business s.r.o.
Chelčického 2288, 767 01 Kroměříž, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 401989-01/01 of: 26.05.2014

A sample of the product was found to be in conformity with:
ČSN EN 61439-2 ed.2:12, ČSN EN 61439-1 ed.2:12

The validity of the certificate is limited to: 31.5.2017

3.6.2014

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



401989-01